



GOVERNMENT OF TAMIL NADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
SANITARY CERTIFICATE

YEAR 2024 - 2025

APPENDIX - 3

(GIVEN UNDER SEC 26, 33 OF TNPH ACT 1939)

R.NO : 6915/ E1/ 2024 , Date: 26.11.2024

Office of the District Health office
Health Services, Ranipet.

I here by declare that I have Inspected
**MMES PUBLIC SCHOOL, C.ABDUL HAKEEM COLEGE OF E & T
CAMPUS, S.F. No: 70/2C & 2D, HAKEEM NAGAR, MELVISHARAM,
WALAJA TALUK, RANIPET DISTRICT - 632 509.**

- : Building and Premises on the day of 25.11.2024 and Certify
- : That the accommodation provided is sufficient and is properly ventilated and lighted;
- : That the building is maintained in Substantial repair;
- : That is neat and clean;
- : That the Latrine arrangements are adequate and satisfactory;
- : That the supply of drinking water is wholesome and
- : That in all other necessary respects the sanitation is good.

With Conditions :

- : SOP should be strictly followed for COVID- 19 in the Campus.
- : Avoid any form of water stagnation and mosquitoes breeding.
- : Display signage boards regarding COPTA - 2003.

This Certificate is valid for ONE year from the date of issue

Countersigned

Signature :

Designation : **DISTRICT HEALTH OFFICER**
Health Services , Ranipet.

Signature :

Designation :

**BLOCK HEALTH SUPERVISOR
GOVT. P.H.C - PUDUPADI
ARCOT BLOCK, PIN-632 503
RANIPETTAI DISTRICT.**

PRINCIPAL
MMES PUBLIC SCHOOL (CBSE)
HAKEEM NAGAR,
MELVISHARAM - 632 509, Ranipet Dt.,

CHAIRMAN
MMES PUBLIC SCHOOL (CBSE)
HAKEEM NAGA
MELVISHARAM - 632 509, Ranipet Dt.,



TEST WATER BEFORE TASTE

twadlabphotos@gmail.com

Ph : 0416 - 2215168

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

District Level Water Testing Laboratory

Opp. To Muthu Mandapam, Old Katpadi Road, Vellore - 632 004.

TEST REPORT

TO:

The Principal,
MMES Public School(CBSE),
Hakeem Nagar,
Melvisharam
Ranipet.632 509

Lr.No.67122-67122A/JWA/Lab/VLR/2025/dt:01.04.2025.

Sir,

Ref : Lr.No: Dated. 27.03.2025

2.T.O Invoice No: 11346,Dated:27.03.2025. For Rs: 1652/-

The result of analysis for the water samples sent under reference is enclosed.

Scheme: PVT

Source : Drinking Water

Date of Collection: 27.03.2025.

Date of Receipt : 27.03.2025.

Location:67122-67122A:MMES Public School(CBSE),Melvisharam

BIS 10500:2012	Acceptable Limit	Maximum permissible limit in the absence of alternative source.	Result
I. PHYSICAL EXAMINATIONS			67122
1. Appearance			Clear
2. Colour			Colourless
3. Odour	Agreeable	Agreeable	None
4. Turbidity NTU	1	5	0
5. Total dissolved solids mg/L	500	2000	136
6. Electrical conductivity micro mho/cm			194
II. CHEMICAL EXAMINATIONS			
7. pH	6.5-8.5	6.5-8.5	6.75
8. Alkalinity Ph as CaCO ₃ mg/L	-	-	0
9. Alkalinity Total as CaCO ₃ mg/L	200	600	40
10. Total Hardness as CaCO ₃ mg/L	200	600	70
11. Calcium as Ca mg/L	75	200	14
12. Magnesium as Mg mg/L	30	100	9
13. Sodium as Na mg/L	-	-	-
14. Potassium as K mg/L	-	-	-
15. Iron Total as Fe mg/L	0.3	1.0	0.00
16. Manganese as Mn mg/L	0.1	0.3	0.00
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.00
18. Nitrite as NO ₂ mg/L	-	-	0.00
19. Nitrate as NO ₃ mg/L	45	45	4
20. Chloride as Cl mg/L	250	1000	25
21. Fluoride as F mg/L	1.0	1.5	0.0
22. Sulphate as SO ₄ mg/L	200	400	14
23. Phosphate as PO ₄ mg/L	-	-	0.00
24. Tids Test 4Hrs.as O ₂ mg/l	-	-	0.0
III. BACTERIOLOGICAL EXAMINATION (M.F.Technique)			67122A
Fecal Coliform(100ml)	-	-	0

Report:67122: The water sample is chemically Potable

Report:67122A: The water sample is Bacteriologically Not contaminated

Junior Water Analyst

TWAD Board

District Water Testing Laboratory,
Vellore - 632 004.

PRINCIPAL
MMES PUBLIC SCHOOL (CBSE)
HAKEEM NAGAR,
MELVISHARAM - 632 509, Ranipet Dt.,

CHAIRMAN
MMES PUBLIC SCHOOL (CBSE)
HAKEEM NAGAR,
MELVISHARAM - 632 509, Ranipet Dt.,